

## ALARM MANAGEMENT - LOAD OUT

ITEM	REV	ADDRESS	DESCRIPTION	TYPE	NOTES
33		L1-D-51	TRAIN LOADING CONTROL ROOM SMOKE DET	ALARM	
34		L1-M-52	TRAIN LOADING CONTROL ROOM NORTH DOOR PS	ALARM	
35		L1-D-53	TRAIN LOADING SCALE HOUSE SMOKE DET	ALARM	
36		L1-M-54	TRAIN LOADING SCALE HOUSE SOUTH DOOR PS	ALARM	
37		L1-M10-60	PULL STATION - NORTH TRAIN LOADING	ALARM	
38		L1-M10-61	PULL STATION - SOUTH TRAIN LOADING	ALARM	
39		L1-M10-62	SPRINKLRE #1	SUPERVISORY	
40		L1-M10-63	SPRINKLRE #2	SUPERVISORY	
41		L1-M10-64	SPRINKLRE LOW AIR	SUPERVISORY	
42		L1-M10-65	SPRINKLRE FLOW	ALARM	
43		L1-M-70	FJB-5 - MONITOR GENERAL	TROUBLE	
44		L1-M-71	FJB-5 - OUTPUT #1	TROUBLE	
45		L1-M-72	FJB-5 - OUTPUT #2	TROUBLE	
46		L1-M-73	FJB-5 - OUTPUT #3	TROUBLE	
47		L1-M-74	FJB-5 - OUTPUT #4	TROUBLE	
48		L1-M-75	FJB-5 - AC FAIL	TROUBLE	
49		L1-M-76	FJB-5 - BATTERY	TROUBLE	
50		L1-M-77	FJB-5 - FAULT	TROUBLE	
51		L1-M-78	FJB-5 - CHARGER	TROUBLE	
52		L1-M-80	FJB-8 - MONITOR GENERAL	TROUBLE	
53		L1-M-81	FJB-8 - OUTPUT #1	TROUBLE	
54		L1-M-82	FJB-8 - OUTPUT #2	TROUBLE	
55		L1-M-83	FJB-8 - OUTPUT #3	TROUBLE	
56		L1-M-84	FJB-8 - OUTPUT #4	TROUBLE	
57		L1-M-85	FJB-8 - AC FAIL	TROUBLE	
58		L1-M-86	FJB-8 - BATTERY	TROUBLE	
59		L1-M-87	FJB-8 - FAULT	TROUBLE	
60		L1-M-88	FJB-8 - CHARGER	TROUBLE	
61		L1-M-41	ELEVATOR HOME	SUPERVISORY	
62		L1-M-42	ELEVATOR SHAFT HEAT DET	ALARM	
63		L1-M-43	SPARE	SUPERVISORY	
64		L1-M-44	SPARE	SUPERVISORY	

