



180-FJB-4

L1-IM6-1-IN - FROM SW ROM #10
 L1-IM6-1-OUT - TO LOCAL DEVICES
 L1-IM6-2-IN - FROM LOCAL DEVICES
 L1-IM6-2-OUT - TO SCALE HOUSE
 L1-IM6-3 TO -6 - SPARES

180-FJB-5

PS1 - 4 CCT POWER SUPPLY
 CTT'S #5 TO #8

180-FJB-6

L1-IM6-1-IN - FROM TRAIN CR
 L1-IM6-1-OUT - TO LOCAL DEVICES
 L1-IM6-2-IN - FROM LOCAL DEVICES
 L1-IM6-2-OUT - TO TRUCK CR
 L1-IM6-3 TO -6 - SPARES

180-FJB-7

L1-M10-60 - NON-ADDR LOOP #2
 L1-M10-61 - NON-ADDR LOOP #3
 L1-M10-62 - SPRINKLER TAMPER #1
 L1-M10-63 - SPRINKLER TAMPER #2
 L1-M10-64 - SPRINKLER LOW AIR PRESS
 L1-M10-65 - SPRINKLER FLOW ALARM
 L1-M10-66 TO -69 - SPARES

L1-IM6-1-IN - FROM SCALE HOUSE
 L1-IM6-1-OUT - TO LOCAL DEVICES
 L1-IM6-2-IN - FROM LOCAL DEVICES
 L1-IM6-2-OUT - TO SW ROOM #10
 L1-IM6-3 TO -6 - SPARES

180-FJB-8

PS2 - 4 CCT POWER SUPPLY
 CTT'S #9 TO #12

180-FJB-9

JUNCTION BOX

NOTES



| | | | | | |
|---|--------|--------------------|----------|------------|--------|
| 6 | | | | PROJECT | |
| 5 | | | | GA | |
| 4 | | | | | |
| 3 | | | | | |
| 2 | | | | TITLE | SAMPLE |
| 1 | AA | ISSUED FOR REVIEW. | YY/MM/DD | | |
| # | BY | DESCRIPTION | DATE | DRAWN | BB |
| | | | | CHKD | CC |
| | | | | CONTRACT # | N/A |
| | PHONE | | | SCALE | NTS |
| | OFFICE | | | DWG. # | 1 of 1 |